



REQUEST FOR CLARIFICATIONS

Project Name: Repair of Damaged Home (Home 1 VG)	Tender No: ITT/0021
Tender Name: Repair of Damaged Home at Virgin Gorda, British Virgin Islands (Home 1 VG)	
Document Revision Date: Wednesday 04 th September 2019	Document Version: 1

#	Request for Clarification	Response to Clarification from RDA
001	<p>Need clarification on BOQ Item D.1.14, Description reads 8' Concrete blockwork to front patio.</p> <p>Whereas, previous BOQ Item C.2.4. Description stated 6" blockwork with alter. pockets filled.</p> <p>Confirmation required on block size.</p>	<p>All concrete blocks will be 8".</p>
002	<p>Please clarify the following description in the BOQ for the following Item:</p> <p>F.2.2 Kitchen Wall mount unit 2'-0" wide x 1'-10" high. Clarify that the width is correct.</p>	<p>The width of the wall mounted kitchen is correct as per Bill of Quantity.</p>
003	<p>Please clarify the following description in the BOQ for the following Item:</p> <p>F.2.3 Stainless Steel bowl kitchen sink.....trap, etc. State size of sink required with or without drain.</p>	<p>Nominal Dimensions: 33" L x 22" W x 6" D (838 x 559 x 152mm)</p> <p>To be connected to existing drain.</p>

Tender enquiries to the RDA can be e-mailed to procurement@bvirecovery.vg
Tender Submission Deadline: 12-Sep-2019 at 4:00PM