



CLARIFICATION NO. 3
23rd March 2022

Project Name: Redevelopment of the Elmore Stoutt High School	Tender No: RDA/ITT/2022/002/ICB
Tender Name: Supply of Fixtures, Fitting & Equipment for the Elmore Stoutt High School Re-development Project	
Bidders Conference / Site Visit Date: N/A	Time: N/A
Location: Elmore Stoutt High School, Tortola	

#	Question	Answer
1.	Window item 4. - You have listed a quantity of 242 for Block B, this do not match quantity of 248 as per drawing	Proceed with quantities indicated on the Drawings. (Refer to updated BOQ.)
2.	Door item 3. - Your quantity of 6 do not exist for Block A, but is listed on drawing for Block B.	Door type 03 is a bathroom stall door. Proceed with quantities indicated on drawings.
3.	Door item 5. - Quantity of 2 does not exist for Block A.	Door type 05 is a bathroom stall door. Proceed with quantities indicated on drawings.
4.	Door item 8. - You have listed a quantity of 18 for Block A, this do not match quantity of 20 as per drawing.	Proceed with quantities indicated on drawings.
5.	Clarification no. 2 is the final with respect to the BOQ?	Yes.
6.	The quantities and descriptions on the BOQ are final. Please note for example the quantity for window W1 in block B1 and Block B2 on the clarification no. 2 states 121 each, however on the drawing it is 248 each.	The drawings will supersede the BQ for this item.
7.	The windows are to be supplied with provision for a shutter or the shutter is to be supplied with the windows?	Refer to window types per drawings and updated BQ's provided. Specific Window and Door types are identified to receive storm shutters that are manually operated. The shutters are to be installed in conjunction with the windows and doors.
8.	The easy close mechanism is to be supplied with the doors?	Yes
9.	The stoppers are to be supplied for the doors.	Yes
10.	All doors to be supplied with the frames to suit the dimensions of the doors	Yes

Deadline for Tenderers to submit subsequent questions / request for clarifications to the RDA at procurement@bvirecovery.vg : 25-Mar-2022