



BIDDERS CONFERENCE & SITE VISIT - QUESTION AND ANSWER NOTES

ITT No: RDA/ITT/2021/006/NCB

Repair Works to the Perimeter Fencing of the Anegada Recreation Ground

CLARIFICATION NO. 1

20th May 2021

We acknowledge receipt of your requests for clarification at the Bidders' Conference and Site Visit on Wednesday 19th May 2021 for the captioned tender. For ease of reference, the responses are in Tables 1 below:

Table 1-Response to Request for Clarification No. 1 dated 19th May 2021

#	Request for Clarification	Client's Response
1.	Do you need both the internal and external of the perimeter fence to be cleared for e.g. of debris, rocks and stumps?	Yes.
2.	What do you propose to put on top of the bar of the fence to the barbed wire?	Refer to Booklet 3 Scope of Works (SOW) Section 5.1.3 to 5.1.9
3.	Based on current market research, we could not source from BVI 3 ¼ galvanize hollow section pile to fit on top of the fence. Can we source from outside of BVI or use an alternative?	Contractors can source outside of the BVI or can use 1 5/8 galvanize hollow section pile.
4.	Are there specifics for the columns available?	Yes, in Booklet 3 of the SOW.
5.	Is the cattle grid formed or is one needed and how far down to do block work?	The cattle grids had to be fabricated with a minimum depth of 8"
6.	When do you intend to start work?	Refer to Booklets 1 & 2A
7.	Are the existing columns along the cemetery to be demolished and rebuilt at different heights?	Yes, based on the drawings provided.
8.	At the inside of the grounds, would a gate be installed to access the cemetery?	Yes.
9.	Suggestion: Install a cattle trap by the post.	Noted.



BIDDERS CONFERENCE & SITE VISIT - QUESTION AND ANSWER NOTES

10.	Is there electricity?	Yes.
11.	Would the contractor be required to erect fencing behind the old bathroom?	Yes.
12.	Will the old (existing) gates be reused?	No, new gates will be installed.
13.	Would the Contractor be allowed to access the cemetery to do works such as painting the fence and tidying the works?	Yes, access will be granted to do said works.
14.	Can Contractors buy materials locally and from non- Caribbean Development Bank (CDB) member countries?	This project is not funded by the CDB. Either way, BVI is a member country of the CDB and Contractors are encouraged to buy their goods locally.

Deadline for Tenderers to submit subsequent questions / request for clarifications to the RDA at procurement@bvirecovery.vg : Monday 31-May-2021