



## QUESTION AND ANSWER NOTES

ITT No: RDA/ITT/2021/006/NCB

### Repair Works to the Perimeter Fencing of the Aneгада Recreation Ground

#### CLARIFICATION NO. 2

28<sup>th</sup> May 2021

We acknowledge receipt of your requests for clarification via e-mail on Friday 21<sup>st</sup> May 2021 and Saturday 22<sup>nd</sup> May 2021 for the captioned tender. For ease of reference, the responses are in Tables 1 below:

*Table 1-Response to Request for Clarification No. 1 dated 21<sup>st</sup> & 22<sup>nd</sup> May 2021*

#	Request for Clarification	Client's Response
1.	<p>We seek detailed information on the cattle grid as follows:</p> <ol style="list-style-type: none"> <li>1. Size/Diameter of steel required</li> <li>2. Distances required for steel placement</li> <li>3. How is the cattle grid secured in place.</li> </ol>	<p>Drawings will be provided to the selected tenderer, however a provisional sum of \$14,000.00 is entered sum in the BoQ. Please see revised BoQ (Amendment 1).</p>
2.	<p>The Drawings show an 8ft high chain link fence and also Booklet 3 Scope of works 5.1.3 speaks of an 8ft high chain link fence, opposed to the BoQ Item F.1.3 which states.</p> <ul style="list-style-type: none"> <li>• Hot dip galvanised chain link fencing 6'-0" high, 2" x 2" mesh, No. 9 guage, 3" diameter PVC poles at 10 feet centres, complete with all necessary fixings, caps, bands, bolts, sleeves etc.</li> </ul>	<p>BoQ description is correct chain link fencing should be 6'-0" high</p>
3.	<p>Confirmation is required on the following.</p> <ol style="list-style-type: none"> <li>1. Height of proposed chain link fence</li> <li>2. Type of 3" PVC Poles - Waste line or Schedule 40</li> </ol>	<ol style="list-style-type: none"> <li>1. Height of proposed chain link fence 6' feet high</li> <li>2. Type of PVC poles - Schedule 40</li> </ol>



### QUESTION AND ANSWER NOTES

	3. The existing 3" poles are concrete filled. Should the proposed poles be concrete filled? If yes, state the strength of concrete.	3. strength of concrete is 4000psi
4.	How many gates are going to be installed?	Three (3) gates will be installed 2 vehicular gates - 14 feet and 12 feet 1 pedestrian gate

**Deadline for Tenderers to submit subsequent questions / request for clarifications to the RDA at [procurement@bvirecovery.vg](mailto:procurement@bvirecovery.vg) : Monday 31-May-2021**