



**CLARIFICATION NO. 2**  
**16<sup>th</sup> May 2022**

<b>Project Name:</b> Re-development of the Elmore Stoutt High School	<b>Tender No:</b> RDA/ITT/2022/005/ICB
<b>Tender Name:</b> Supply of finishes (Paint, Primer, and Epoxy Waterproof Coating) for the Elmore Stoutt High School Re-development Project	
<b>Bidders Conference / Site Visit Date:</b> May 5th, 2022	<b>Time:</b> 10:00 am
<b>Location:</b> RDA's Conference Room (White Cedar)	

#	Question	Answer
1.	<p>The floor epoxy for the walkways: I understand the black marble flakes are to be added, along with the non-skid in the final coat. My question is the colour of the epoxy base. It can be clear (will see the background concrete colour plus more of the marble flakes) or one of a variety of colours (will not see any background, just the epoxy colour and LESS of the flake colour), all with differing prices. Please advise on the choice, clear vs which colour.</p>	<p>Please note that the specifications for the application of the product call for tinted primer and first base. I suggest from the color chart "Armor Gray". This will properly complement with the marble flakes.</p>
2.	<p>Can you all issue a new BoQ separating the following sqyd for:</p> <ul style="list-style-type: none"> <li>• Interior walls</li> <li>• Exterior walls</li> <li>• Celing area</li> <li>• Flooring epoxy area</li> <li>• Roof elastomeric area</li> </ul>	<p>No. Proceed per provided BoQ</p>
3.	<p>The tender documents are not clear. ie Itb 2.2 states supply...then BQ states Prepare Surface and Apply. Please advise further.</p>	<p>This tender is for supply only. No application or installation included within.</p>

**Deadline for Tenderers to submit subsequent questions / request for clarifications to the RDA at [procurement@bvirecovery.vg](mailto:procurement@bvirecovery.vg) : 20-May-2022**